



Monthly Fire Extinguisher Inspection Checklist

Date of Inspection: _____

Conducted by: _____

Inspection of all fire extinguishers includes the following. Check to confirm inspection items were conducted. Note any deficiencies found in the notes section below.

I certified the following:

- Extinguishers are installed in designated places.
- There is no obstruction to access or visibility.
- Operating instructions are on the nameplate and are legible and facing outward.
- Safety seals and tamper indicators are not broken or missing.
- The extinguisher is full (Fullness is determined by weighing or “hefting”).
- Extinguisher was examined for obvious physical damage, corrosion, leakage, or clogged nozzle.
- Pressure gauge reading or indicator is in the operable range or position.
- Condition of tires, wheels, carriage, hose, and nozzle is okay (for wheeled units).
- HMIS label is in place.
- Extinguisher tag signed and dated at time of inspection.

If an inspection of any fire extinguisher reveals a deficiency in any of the conditions listed above, corrective action (recharge, hydro test, six-year maintenance) shall be performed per NFPA 10.

NOTE: Fire extinguishers shall be visually inspected in accordance with 7.2.2.2 if they are located where any of the following conditions exists:

1. High frequency of fires in the past
2. Severe hazard area
3. Locations that make fire extinguishers susceptible to mechanical injury or physical damage.
4. Exposure to abnormal temperatures or corrosive atmospheres.

NOTES:

Safeguard your facility today.  Call 540.667.5078